

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 38

Dated: 28/06/25

It is certified that an inspection team headed by RANVIJAY KUMAR, CHEMIST

(Name of Officers with designation) from D. L. L. SASARAM PHED

inspected the AMALTA NIKETAN, TILOTHU, ROHTAS (BIHAR) 821312

(Name & Address of the school) on 25/06/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. SRM/W/25-26/R/38 dated 28/06/25

of D. L. Laboratory, Sasaram (PHED Lab) certified that the

AMALTA NIKETAN (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 24/06/2026.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : PHED

S. K. Singh
Technical Manager
PHED Sasaram (Rohtas)
A. E. Com. Technical Manager

To

AMALTA NIKETAN
TILOTHU, ROHTAS, (BIHAR)
(Name & Address of the Institution) 821312

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Suresh Kumar Shukla
Manager
Amaltas Niketan
(A unit of Tilothu Mahila Mandal)



TC-14408

District Level Laboratory PHED, Sasaram, Rohtas
Old G.T. Road, Near Railway Station, Sasaram, (Rohtas)
eephedrohtas@gmail.com Ph.No :- 8544428572/8544428639



बिहार सरकार

TEST REPORT

Name & Address Of the Customer :- AMALTAS NIKETAN, TILAO THU, ROHTAS BIHAR, PIN - 821312	Report No.	: SRM/W/25-26/R/ 38
	Date	: 28/06/2025
	Sample No.	: SRM/W/25-26/38
	Sample Description	: Drinking Water
	Sample Mark/ Location	: AMALTAS NIKETAN
	Sample Collected On	: 23/06/2025
	Sampling Plan & Method	: IS 3025(Part 1)
	Date of Performance (s)	: 23/06/2025 to 28/06/2025
	Ref No. Date	: App/219/25

Analysis Result

Sl. No.	Test Parameter	Test Method	IS 10500:2012 Amd. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	pH	IS 3025(Part 11) : 2022	6.5-8.5	NR	7.12
2	Turbidity	IS 3025(Part 10) : 2023	1 NTU	5 NTU	<0.5
3	TDS	IS 3025(Part 16) : 2023	500 mg/L	2000 mg/L	768
4	Total Hardness	IS 3025(Part 21) : 2019	200 mg/L	600 mg/L	202
5	Calcium	IS 3025(Part 40) : 2023	75 mg/L	200 mg/L	55.6
6	Magnesium	APHA 24rd Edition -3500-Mg Method B (Calculation Method) : 2023	30 mg/L	100 mg/L	15.34
7	Iron	APHA 23rd Edition -3500-Fe Method B (Phenanthroline Method) : 2023	1 mg/L	NR	0.1
8	Chloride	IS 3025(Part 32) : 2019	250 mg/L	1000 mg/L	94
9	Total Alkalinity	IS 3025(Part 23) : 2023	200 mg/L	600 mg/L	306
10	Fluoride	APHA 23rd Edition -4500-F Method C (Electrode Method) : 2023	1 mg/L	1.5 mg/l	0.1
11	Colour	IS 3025 (Part 4) : 2021	5	15	<1
12	Odour	IS 3025 (Part 5) : 2022	Agreeable	Agreeable	Agreeable
13	Taste	IS 3025 (Part 8) : 2023	Agreeable	Agreeable	Agreeable

Reviewed

[Signature]

Chemist

D.L.L Sasaram, Rohtas
P.H. DIVISION, SASARAM

Authorized

Quality Manager

D.L.L Sasaram, Rohtas

Disclaimer:

- The result relates only to the items(S) tested
- The report shall not be reproduced except in full, without approval of the laboratory
- The reserved part of water samples (s) shall be retained for 15Days from the date of issue of the test Report.
- The laboratory is responsible for all the information given in the report.



[Signature]
Manager
Amaltas Niketan
(A unit of Tilaothu Mahila Mandal)